



MUNICIPAL WATER USE INSPECTION FORM

DATE: OCTOBER 16, 1995 COMPANY REP.: Mina McLeod
 LICENSEE: HAMLET OF AKLAVIK LICENCE #: N3L4-0570

WATER SUPPLY

Source (s): MACKENZIE RIVER, PEEL CHANNEL Quantity Used (to date): unknown
 Owner/Operator: Owner = GNWT; Operator = GNWT (estimate or actual)

Indicate: **A - Acceptable U - Unacceptable N/A - Not Applicable**

Intake Facilities: A Storage Structure A Treatment Systems A Chem. Storage A
 Flow Meas. Device A Convey. Lines N/A Pumping Stations A

Comments: Hamlet had a "Boil Water Order" in the summer of 1995 for approximately 8 weeks. High turbidity was the reason. Apparently the treatment plant has a capacity of only 400 people. The Hamlet population is almost 600.

WASTE DISPOSAL

Sewage Sewage Treatment System (primary, secondary or tertiary) primary
 Natural Water body Continuous Discharge (land or water)
 Seasonal Discharge _____ Wetlands Treatment _____ Trench _____

Solid Waste: Owner/Operator: Owner - GNWT; Operator = Hamlet
 Landfill _____ Burn & Landfill Other _____

Indicate: **A - Acceptable U - Unacceptable N/A - Not Applicable**

Disch. Quality A Decant Structure N/A Erosion N/A
 Disch. Meas. Dev. A Dyke Inspection N/A Seepages N/A
 Dams, Dykes A Freeboard N/A Spills N/A
 Construction A O & M Plan A A & R Plan N/A

Periods of Discharge: A Effluent Discharge Rate: ≈ 0.5 m³/s

Comments: SNP stations not posted. Samples at SNP 570-3 were not taken before freeze-up.

FUEL STORAGE

Owner: N/A Operator _____ Condition of Tanks _____
 Berms & Liners _____ Water within berm: _____ Evidence of Leaks: _____
 Drainage Pipes _____ Pump Station and Catchment Berm _____
 Pipeline Condition _____ Not Applicable: _____

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) None since spring 1995.

(DIAND) SNP 570-1 (raw H₂O) at time of inspection

Signs Posted: SNP only SNP 570-1, the others were not. Warning yes.

Record & Reporting Acceptable except Annual Report should mention any maintenance and/or modifications.

Geotechnical Inspection: N/A

Non-Compliance of Act or Licence: Violations: 1. SNP Part B, item 1: There was no sample taken prior to freeze up in 1995. 2. Part A, item 9: SNP 570-3 and 570-4 were not posted.

Page 2 attached Yes _____ No X

UTILITY DATA CLERK
 Licensee Representatives Title
M. McLeod
 Licensee Representatives Signature

SCOTT GALLUPE
 Inspectors Name
[Signature]
 Inspectors Signature