



OCT 28 1997

MUNICIPAL WATER USE INSPECTION FORM

DATE: October 14, 1997

WATER RESOURCES DIVISION COMPANY REP: Ron Sayer - Assistant Hamlet Foreman

LICENSEE: Hamlet of AKLAVIK

LICENCE #: N324-0570

WATER SUPPLY

Source (s): Mackenzie River / Peel channel Quantity Used (to date): unknown


Owner/Operator: Owner = GNWT, Operator = GNWT (estimate or actual)

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Intake Facilities: A Storage Structure A Treatment Systems A Chem. Storage A

Flow Meas. Device A Convey. Lines N/A Pumping Stations A

Comments: NO PROBLEMS NOTED WITH WATER SUPPLY. #6



WASTE DISPOSAL

Sewage Sewage Treatment System (primary, secondary or tertiary) Primary

Natural Water body [checked] Continuous Discharge (land or water) [checked]

Seasonal Discharge [] Wetlands Treatment [] Trench []

Solid Waste: Owner/Operator: GNWT owner GNWT operator

Landfill [] Burn & Landfill [checked] Other []

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Disch. Quality A Decant Structure N/A Erosion N/A

Disch. Meas. Dev. A Dyke Inspection N/A Seepages N/A

Dams, Dykes A Freeboard N/A Spills N/A

Construction A O & M Plan A A & R Plan N/A

Periods of Discharge: A Effluent Discharge Rate: NATURAL OUTFLOW. #6

Comments: SNP station 570-3 still not posted. Please place a sign at SNP station 570-3. #6

COPY	BOARD	G.W.	E.A.	W. RES.	FILE
				0570	

FUEL STORAGE

Owner: [] Operator [] Condition of Tanks []

Berms & Liners [] Water within berm: [] Evidence of Leaks: []

Drainage Pipes [] Pump Station and Catchment Berm []

Pipeline Condition [] Not Applicable: []

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) NONE PRIOR TO FREEZE-UP. #6

(DIAND) INSPECTOR TOOK SAMPLES SNP 570-1 (RAW WATER).

Signs Posted: SNP Only SNP 570-01 Warning YES. #6

Record & Reporting Hamlet did not submit 1996 annual Report yet. Please ensure that a report is submitted

Geotechnical Inspection: N/A #6