

COPY	
BOARD.	6
G.W.	1
E.A.	1
W. RES.	0016
File-	1525

**ANNUAL REPORT Re Water Licence No N7L3-1525  
HAMLET OF HOLMAN**

May 15, 2001


As per requirements, please find the information for the Hamlet of Holman's annual report.

1.a)d)

Month	Litres Water Delivered	Litres of Sewage Disposed
January	1,049,695	1,049,695
February	761,549	761,549
March	1,592,831	1,592,831
April	1,027,713	1,027,713
May	1,106,698	1,106,698
June	1,052,904	1,052,904
July	1,087,874	1,087,874
August	1,219,621	1,219,621
September	1,135,150	1,135,150
October	1,186,187	1,186,187
November	971,712	971,712
December	788,991	788,991



Total water consumption was 12,980,925 litres down from 14,255,810 litres the previous year.



As noted in the 2000 Annual Report, there is no longer any pick-up of bagged sewage in the Hamlet of Holman. For cabin usage etc., we maintain a small pit but we do not maintain a log.

1.b) During the summer of 2000, the following improvements were made to the Holman facilities. The "honey bag" pit was closed at the sewage disposal facilities and was moved to the solid waste site. Minor O&M work at the berm was completed and further work to rectify problems with offload chute are planned for the summer of 2001.

Most of the work during 2000 was at the solid waste site. This work included:

- moving the "dead animal pit" to a more suitable location
- creating a cell for "honey bag" disposal at the solid waste facility
- creating a bermed area for storage of waste oil drums
- repair/replacement of fencing
- general clean-up and stockpiling of gravel for cover.

At the water source, ongoing maintenance was provided to the pump station, but no other work was done at the site.

Water metres are now in use in most units in the community.

For the upcoming year, minor upgrades are planned for each facility including further work on the chute and berm at the sewage disposal facility. At the solid waste site, there will be continued clean-up and stockpiling of gravel. There will be ongoing regular maintenance at the water fill station.

If you have any question on the above, please do not hesitate to contact me.

Sincerely,

*Eleanor Young*  
 Eleanor Young  
 Senior Administrative Officer

