

**2001 ANNUAL REPORT Re Water Licence No N7L3-1525  
HAMLET OF HOLMAN**

April 12, 2002

As per requirements, please find the information for the Hamlet of Holman's annual report.

1.a)d)

Month	Litres Water Delivered	Litres of Sewage Disposed
January	1,194,970	1,194,970
February	1,023,510	1,023,540
March	1,134,289	1,134,289
April	962,257	962,257
May	1,221,058	1,221,058
June	1,026,902	1,026,902
July	947,517	947,517
August	1,423,264	1,423,264
September	1,280,876	1,280,876
October	1,305,306	1,305,306
November	1,095,178	1,095,178
December	1,570,747	1,570,747

Total water consumption was 14,186,904 litres. This was down from the 12,980,925 litres consumed in 2000 but very close to the 1999 consumption of 14,255,810.

As noted in the previous two reports, we maintain a small bagged sewage pit primarily for cabin useage as there all units oprating in Holman have full running-water systems.

1.b)


The work at the sites during 2001 was primarily of an annual maintenance nature. Continued work was done at the solid waste site to stockpile gravel and pushing/compacting waste. In addition, we attempted to use a waste oil burner (kindly donated by NTPC) to dispose of the some the waste oil accumulated in drums at the site. This was a very slow process and the burner was damaged in the wind, so not all of the waste oil has been disposed of at this time. We are working with RWED to look at the purchase of a new burner to complete this work.

At the water source, ongoing maintenance was provided to the pump station, but no other work was done at the site. At the sewage lagoon, minor work was done on the berm and offloading area as part of the annual maintenance.

For the coming year, we anticipate that additional site work will be done at the scwage lagoon to continue maintenance and stability of the berm. Some small work may be done at the water source in terms of putting up some safety rails to protect the workers as they load their trucks with water. No work is intended to the site itself.

If you have any question on the above, please do not hesitate to contact me.

Sincerely,

  
Eleanor Young  
Senior Administrative Officer